


#### NOTES:

1. THE SDPA ENCLOSURE MUST BE EARTHED.
2. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
3. INPUT REQUIRE 'C' CONNECTED TO THE NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
4. CONNECTIONS TO CON2 & 3 MUST BE ON THE SAME PHASE AS THE SUPPLY ON CON 1.  
THIS UNIT IS NOT RATED FOR 415V

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

		<b>JTL SYSTEMS LTD</b> 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE: RG14 5SJ TEL: 01635 263646 FAX: 01635 263647	
ISSUE	DESCRIPTION	APP'D	DATE
1	ORIGINAL ISSUE	MJK	09/05
TITLE: <b>CABINET CONTROLLER (PT1000 SENSORS) CONNECTIONS</b>			
TYPE: SDPA			
PROJ.	DRG No:	SHT	OF
	03222	1	1
		ISS.	1