

JTL FIRMWARE VARIATIONS		LACN
VERSION	DESCRIPTION	DATE
v0.00.0	Original Issue	May 2004
v0.00.1	Man trapped alarm added. Input 2 selection function added on item 138. Input 2 status moved from item 71 to 139. Defrost recovery operation corrected. Invert plant alarm input, Item 66, added. Was missing from v0.00.0 Plant alarm input operation corrected.	Dec 2004
v0.00.2	Coldroom temperature alarm strategy changed to work on air off and pipe sensors as necessary when sensor faulty. Alarm strategy now follows control strategy. Coldroom temperature now displayed on item 20 separately from air on temperature on item 21.	Apr 2005
v0.00.3	Start of time now 1 st Jan 2004. Defrost co-ordination present timer operation corrected. Exclude from optimisation error corrected. Absolute humidity broadcast data added on item 246. Time since start of last defrost added.	June 2007
v0.00.4	Calculation of time since start of last defrost corrected. Forced defrost requirement now handled as standard defrost requirement. Theoretical potential lockup prevented when network defrost command occurs during defrost recovery.	Nov 2007
v0.00.5	Display choice added on item 129 to allow use of backlit LCD display. Deadband control added on item 140. Choice of control on air off or air on temperature added item 275.	Nov 2008