

JTL FIRMWARE VARIATIONS		LACI
VERSION	DESCRIPTION	DATE
v0.00.0	Development release.	Dec 2007
v0.00.1	External PEV override setting added. Service log error corrected. Choice added for 7 bar transducer on item 175. Bitswitch defaults changed from ice cream to Frozen food for non CO2 use. Refrigerant choice for R404, R408 and R507 operation corrected.	Apr 2008
v0.00.2	Incomplete external PEV shutdown operation completed.	July 2008
v0.00.3	Control temperature can be selected as air off or cabinet on item 275. Fixed superheat control strategy added, selectable using item 188. Setpoint reuses item 189. Deadband added for temperature control when working with fixed and limited superheat control.	July 2008
v0.00.4	Override freezes control integral. PI output modified when on fixed superheat control when superheat less than setpoint. Integral term output displayed on item 276.	July 2008
v0.00.5	Pressure transducer fault ranges now depend on transducer selection. Proportional term displayed on item 277. On fixed superheat control a fixed deadband added above the setpoint where the integral is frozen.	July 2008
v0.00.6	Dependencies corrected on items 204, 276 and 277.	July 2008
v0.00.7	Display changed to backlit LCD13 only.	Oct 2008
v0.00.8	Error in factory settings range handling corrected. Error affected all versions. Did not cause any functional problems. Door functions removed. Man trapped alarm added on input 2. Shutdown (plant fault) moved to input 1.	Oct 2008