

CONTENTS

1. Jnet NETWORK IDENTIFICATION	2
2. TEMPERATURES	2
2.1 CABINET (EVAPORATOR 1)	2
2.2 AIR CURTAIN (EVAPORATOR 2)	2
3. TEMPERATURE ALARMS	3
3.1 CABINET (EVAPORATOR 1)	3
3.2 AIR CURTAIN (EVAPORATOR 2)	3
4. CABINET TEMPERATURE CONTROL	3
5. INPUTS & OUTPUTS	3
6. DEFROST CONTROL	4
6.1 DATA & STRATEGIES	4
6.2 SUCTION INITIATED DEFROST	4
6.3 Jnet NETWORK INITIATED DEFROST	4
6.4 DEFROST TERMINATION	4
6.5 DEFROST FORCING FUNCTIONS	4
7. RESTORE FACTORY DEFAULTS	5
8. SYSTEM ALARMS	5
9. DIAGNOSTIC & TEST FUNCTIONS	6
DISPLAY DATA	7

JTL CABINET CONTROLLER ITEM NUMBERS					ECDC	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
1. Jnet NETWORK IDENTIFICATION						
0	Unit type (v0.00.2 on)	Ecdc	Unit type			
19	Software Version number					
1	Unit number				0.1 - 899.9	
2. TEMPERATURES						
The ECDC controller is designed for use with 2 evaporators. Evaporator 1 controls the "inner" cabinet temperature while evaporator 2 controls the "outer" air curtain temperature.						
2.1 CABINET (EVAPORATOR 1)						
20	Estimated cabinet temperature (calculated from Air on and Air off temperatures using the cabinet temperature ratio Item 33)					
33	Cabinet temperature ratio				20 - 80	50
21	Air on temperature					
61	Air on sensor selection	OFF AO.En	Disabled Enabled		0 - 1	A0.En
22	Air off temperature					
62	Air off sensor selection	OFF A.1.En	Disabled Enabled		0 - 1	A.1.En
23	Evaporator temperature					
64	Evaporator sensor selection	OFF E.1.En	Disabled Enabled		0 - 1	E.1.En
24	Suction line temperature					
66	Suction line sensor selection	OFF S.1.En	Disabled Enabled		0 - 1	S.1.En
25	Superheat Evaporator temp - suction line temp					
2.2 AIR CURTAIN (EVAPORATOR 2)						
26	Air off temperature					
63	Air off sensor selection	OFF A.2.En	Disabled Enabled		0 - 1	A.2.En
27	Evaporator sensor temperature					
65	Evaporator sensor selection	OFF E.2.En	Disabled Enabled		0 - 1	E.2.En
28	Suction line sensor temperature					
67	Suction line sensor enabled	OFF S.2.En	OFF Enabled		0 - 1	S.2.En
29	Superheat (Evaporator temp - suction line temp)					

JTL CABINET CONTROLLER ITEM NUMBERS					ECDC						
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE					
				4321							
3. TEMPERATURE ALARMS											
There are 2 overtemperature alarms on the ECDC controller											
a) Air off temperature (cabinet temperature evaporator) b) Air off temperature (air curtain evaporator)											
Both alarms use a common overtemperature tolerance averaging period.											
32	Overtemperature alarm tolerance			xxCC xxCO xxOC xxOO	0 - 20 0 - 20 0 - 20 0 - 20	10 10 5 10					
47	Period over which averages are taken (v0.00.2 on)				00:30 - 03:00	01:00					
3.1 CABINET (EVAPORATOR 1)											
38	Average Air off temperature error										
30	Air off temperature setpoint (target for item 22)			xxCC xxCO xxOC xxOO	-39 to -20 -39 to -20 -10 to +5 -10 to +5	-20 -30 -1 +1					
3.2 AIR CURTAIN (EVAPORATOR 2)											
39	Average Air off temperature error										
31	Air off temperature setpoint (for alarm purposes only)			xxCC xxCO xxOC xxOO	- 39 to -20 - 39 to -20 - 10 to +5 - 10 to +5	- 27 - 36 - 4 - 2					
4. CABINET TEMPERATURE CONTROL											
The temperature control strategy for the ECDC controller is for cabinets which have an air curtain to minimise the cabinet temperature variations. The air curtain temperature is not controlled by the ECDC controller, only monitored. The cabinet temperature is controlled by setting a fixed air off temperature on item 30 which is the target for the air off temperature displayed on item 22.											
30	Air off temperature setpoint			xxCC xxCO xxOC xxOO	-39 to -20 -39 to -20 -10 to +5 -10 to +5	-20 -30 -1 +1					
5. INPUTS & OUTPUTS											
70	Operating mode	rEFr dEFr dF.rc	Refrigeration Defrost Defrost recovery								
71	Defrost input (v0.00.2 on)	OFF dF.IP	No input Defrost input on								
72	Defrost relay	oFF dt.on	Contacts open Contacts closed								
73	Liquid solenoid relay (controlled by cabinet air off temperature)	OFF LS.on	Off Demanding refrig.								

JTL CABINET CONTROLLER ITEM NUMBERS						ECDC					
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE					
				4321							
6. DEFROST CONTROL											
6.1 DATA & STRATEGIES											
40	Duration of last defrost										
41	Time since end of last defrost										
42	Duration of current defrost										
45	Defrost strategy (v0.00.2on)	0 1	CU.In SL.in	Network initiated Suction initiated	0 - 1	SL.In					
69	No of defrosts expected per day (v0.00.2on)	0 1 - 6		Function disabled No of defrosts	0 - 6	3					
6.2 SUCTION INITIATED DEFROST											
58	Defrost initiation temperature (air curtain suction line sensor)			xxCC xxCO xxOC xxOO	-5 - +20 -5 - +20 0 - 20 0 - 20	0 0 +15 +10					
6.3 Jnet NETWORK INITIATED DEFROST											
46	Jnet Network initiated defrost command status (v0.00.2on)	P.dEF F.dEF 0	Defrost Forced defrost No command								
6.4 DEFROST TERMINATION											
50	Defrost termination temperature (air curtain air off sensor)			xxCC xxCO xxOC xxOO	0 - 20 0 - 20 0 - 20 0 - 20	15 15 12 20					
57	Maximum defrost duration			xxCC xxCO xxOC xxOO	00:05 - 00:40 00:05 - 00:40 00:05 - 01:00 00:05 - 01:00	00:20 00:20 00:20 00:40					
49	Liquid hold off duration (for defrost initiated by voltage free contact - Item 71 or network initiation) (v0.00.2on)				00:00 - 00:10	00:00					
6.5 DEFROST FORCING FUNCTIONS											
Forced functions remain forced if the Maintenance Unit remains plugged in. They are automatically cancelled 30 minutes after the Maintenance Unit is unplugged.											
77	Forced defrost	OFF Fd.on	Off Forced defrost on		0 - 1						
78	Inhibit defrost	OFF no.dF	Off No defrosts		0 - 1						
79	Forced refrigeration (v0.00.3on)	OFF Fr.on	Off Forced refrigeration		0 - 1						

JTL CABINET CONTROLLER ITEM NUMBERS					ECDC						
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE					
				4321							
7. RESTORE FACTORY DEFAULTS											
To set the factory defaults into the memory of the controller, first set the bitswitches as shown, then set item 9 to 1. This should be done on initial commissioning of the unit or when the unit is being installed as a replacement part.											
9	Set default values selected by Bitswitch Note: Setting the bitswitches alone has no effect.	1	Set default values	xxCC xxCO xxOC xxOO	Frozen food Ice cream Chiller Produce (off cycle) where C = CLOSED or ON O = OPEN or OFF x = Don't care For unmarked switches C = dot visible O = dot not visible						
8. SYSTEM ALARMS											
80	Group alarm 81 - 88	0 1 - 255	No alarms Check 81 - 88								
81	Cabinet air off overtemperature	CLr A.1.Ht	No fault Fault								
82	Air curtain air off overtemperature	CLr A.2.Ht	No fault Fault								
83	Air on sensor fault	CLr AO.Pr	No fault Fault								
84	Cabinet air off sensor fault	CLr A.1.Pr	No fault Fault								
85	Air curtain air off sensor fault	CLr A.2.Pr	No fault Fault								
86	Sensor power supply fault	CLr PS.Ft	No fault Fault								
87	Unit number corrupted/not set	CLr Un.CF	No fault Fault								
88	All sensors faulty, deselected or disconnected	CLr t.SEn	No fault Fault								
90	Group alarm 91 - 98	0 1 - 255	No alarms Check 91 - 98								
91	Cabinet evaporator sensor fault	CLr E.1.Pr	No fault Fault								
92	Air curtain evaporator sensor fault	CLr E.2.Pr	No fault Fault								
93	Cabinet suction line sensor fault	CLr S.1.Pr	No fault Fault								
94	Air curtain suction line sensor fault	CLr S.2.Pr	No fault Fault								
95	Expected defrosts have not been detected (v0.00.2on)	CLr dEF.F	No fault Fault								

JTL CABINET CONTROLLER ITEM NUMBERS					ECDC	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
9. DIAGNOSTIC & TEST FUNCTIONS						
6	Communications speed (in kilo baud)	600 4800	Baud rate Baud rate			
8	Bitswitch setting (v0.00.2on)	0 1 2 3	Frozen food Ice cream Chiller Produce (off cycle)	xxCC xxCO xxOC xxOO		
89	Sensor excitation value (Factory test)		Not used			
99	Test digital display	CLr SEt	Not active Test active		0 - 1	
101			Not used			
10	Processor alarms (11 - 17)	0 1 - 255	No alarms Check 11 - 17			
11	Static RAM fault	CLr rA.Ft	No fault Fault			
12	Program/counter fault	CLr PC.Ft	No fault Fault			
13	Stack pointer fault	CLr SP.Ft	No fault Fault			
14	Background loop fault	CLr bL.Ft	No fault Fault			
15	PROM checksum fault	CLr Pr.Ft	No fault Fault			
16	NVRAM fault	CLr n.Ft	No fault Fault			
17	Instruction TRAP fault	CLr tP.Ft	No fault Fault			

DISPLAY DATA		ECDC
NORMAL DISPLAY		
-99 ^c	Cabinet temperature (item 20 rounded)	
dEF	Defrost	
dEFr	Defrost recovery	
--	Display data error	
ALARM TEXT (in descending priority order)		
t.SEn	All probes faulty, deselected or disconnected	
Ht	High air off 1 or air off 2 temperature	
OTHER TEXT		
JTL	Start-up text	
SEtP	Air off 1 setpoint data follows this text	
A.On	Air on temperature follows this text	
1.oFF	Air off 1 temperature follows this text	
2.oFF	Air off 2 temperature follows this text	
1.EVP	Evaporator 1 temperature follows this text	
2.EVP	Evaporator 2 temperature follows this text	
1.Suc	Suction line 1 temperature follows this text	
2.Suc	Suction line 2 temperature follows this text	
1.tdF	Temperature difference 1 (Superheat 1) follows this text	
2.tdF	Temperature difference 2 (Superheat 2) follows this text	
L.dEF	Time since end of last defrost follows this text	