

CONTENTS

1. Jnet NETWORK IDENTIFICATION	2
2. TEMPERATURES	2
3. TEMPERATURE ALARMS	2
4. TEMPERATURE CONTROL	3
5. ELECTRONIC EXPANSION VALVE CONTROL	4
5.1 OPERATIONAL SUPERHEAT	4
5.2 Jnet NETWORK AUTOMATIC PRESSURE TRANSDUCER CALIBRATION	5
5.3 ELECTRONIC EXPANSION VALVE CONTROL DATA	6
5.4 ELECTRONIC EXPANSION VALVE OVERRIDE DATA	7
5.5 ELECTRONIC EXPANSION VALVE MODIFIER DATA	7
6. INPUTS & OUTPUTS	8
7. SUCTION PRESSURE OPTIMISATION	9
8. DEFROST CONTROL	10
8.1 DATA & STRATEGIES	10
8.2 REAL TIME INITIATED DEFROST TIMES	11
8.3 SUCTION INITIATED DEFROST	11
8.4 CONTACT INITIATED DEFROST	11
8.5 Jnet NETWORK INITIATED DEFROST	11
8.6 DEFROST METHOD DATA	12
8.7 DEFROST TERMINATION	13
8.8 DEFROST FORCING FUNCTIONS	13
9. FAN CONTROL	14
10. DOOR MONITORING	14
11. Jnet COMMAND FUNCTIONS	14
12. DISPLAY FUNCTIONS	15
13. CLOCK CALENDAR	15
14. RESTORE FACTORY DEFAULTS	15
15. SYSTEM ALARMS	16
16. DIAGNOSTIC & TEST FUNCTIONS	17
DISPLAY DATA	18

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
1. Jnet NETWORK IDENTIFICATION						
0	Unit type	LciS	Unit type			
19	Software Version number					
1	Unit number				0.1 - 899.8	
2. TEMPERATURES						
Note: From version 0.01.3 the temperatures can be displayed on the maintenance unit in degrees Celsius or Fahrenheit. The choice is made on item 122. All setpoint ranges in this document are shown in celsius.						
21	Air on temperature (coldstore)					
36	Air on sensor selection	OFF AO.En	Disabled Enabled		0 - 1	AO.En
22	Air off temperature					
37	Air off sensor selection	OFF AF.En	Disabled Enabled		0 - 1	AF.En
23	Evaporator temperature					
38	Evaporator sensor selection	OFF EP.En	Disabled Enabled		0 - 1	EP.En
24	Suction line temperature					
39	Suction line sensor selection	OFF SP.En	Disabled Enabled		0 - 1	SP.En
25	Superheat (Evaporator temp - suction line temp)					
141	Termination sensor temperature (v0.01.3 on)					
147	Termination sensor selection (v0.01.3 on)	OFF TS.En			0 - 1	OFF
247	Site temperature (from broadcast) (v0.01.1 on)					
248	Site humidity (from broadcast) (v0.01.0 on)					
122	Temperature display unit choice (v0.01.0 on)	CELS FAhr	Celsius Fahrenheit		0 - 1	CELS
3. TEMPERATURE ALARMS						
127	High temperature alarm inhibited selection (v0.00.8 on)	OFF A.inh	Alarms enabled always Alarms inhibited during defrost		0 - 1	OFF
26	Average coldstore temperature error					
32	Coldstore overtemperature alarm tolerance	0.0	Disable Ht alarm (v0.01.0 on)	xxCC xxCO xxOC xxOO	0 - 20 0 - 20 0 - 20 0 - 20	10 10 5 10
47	Period over which averages are taken				00:30 - 03:00	02:00

JTL COLDSTORE CONTROLLER ITEM NUMBERS						LCIS			
ITEM	DESCRIPTION	CODE		CODE MEANING	BIT	RANGE	ITEM 9 VALUE		
		4321							
4. TEMPERATURE CONTROL									
67	Isolate coldroom	run ISOL		Normal operation Coldroom isolated		0 - 1	run		
30	Coldstore temperature setpoint (target for item 21)				xxCC xxCO xxOC xxOO	- 30 to -12 - 30 to -12 - 5 to +25 - 5 to +25	- 20 - 26 0 +4		
48	Max starts/hour (Anti-shortcycling timer when using liquid valve relay to control a condensing unit)	0 1 2 3	unLm 10.PH 15.PH 20.PH	Unlimited 10 starts per hour 15 starts per hour 20 starts per hour		0 - 3	unLm		
28	Current Air off temperature setpoint (calculated by controller)								
29	Current Evaporator temperature setpoint (calculated by controller)								
240	Liquid line valve open percentage for last sample period (v0.01.5 on)								
241	Average liquid line valve open percentage over data logging interval period (v0.01.5 on)								

JTL COLDSTORE CONTROLLER ITEM NUMBERS						LCIS					
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE					
				4321							
5. ELECTRONIC EXPANSION VALVE CONTROL											
Note: From version v0.01.0 pressures can be displayed on the maintenance unit in psi, bar or kPa. The choice is made on item 179. All setpoint ranges in this document are shown in psi. (Note: for electronic expansion valve [PEV] control, item 160 must be set on)											
5.1 OPERATIONAL SUPERHEAT											
161	Control strategy	2t Pt1	2 temperature Pressure transducer		1 - 2	Pt1					
156	Operational Superheat (determined by strategy set on item 161)										
152	Suction line temperature										
151	Evaporator temperature										
155	Suction pressure (guage)										
158	Pressure transducer zero offset				v0.00.0						
					-7.0 to +7.0	0.0					
					v0.00.1 on						
					-10.0 to +10.0	0.0					
159	Auto zero pressure transducer offset (v0.00.7 on)										
175	Pressure transducer type and load resistors (v0.00.1 on)	0 1 2 3	nonE 18 - 2 18 - 1 07 - 1	None selected PTXV18 on 449 PTXV18 on 250 PTXV07 on 250		v0.00.1 - 0.00.2					
					1 - 3	18 - 2					
					v0.00.3 on						
					1 - 3	7 - 1					
176	Pressure transducer location (v0.00.1 on)	0 1 2 3	0 in undr Air	Feature not used In evaporator Under cabinet In ambient air	0 - 3	0					
177	Pressure transducer calibration method Note: Auto zero adjustment is shown on item 159. Network zero adjustment is shown on item 206.	v0.00.2 - v0.01.2									
		off A.Pt.O		None Auto zero	0 - 1	off					
		v0.01.3 on									
		0 1 2	nonE A.Pt.O nEt.A	None Auto zero Network adjustment	0 - 2	nonE					
178	Rate of fall of superheat to trigger auto zero sequence (°C/min) (v0.00.2 on)				1.0 - 10.00	3.0					
179	Pressure display unit choice (v0.01.0 on)	0 1 2 3	nonE PSI bAr PASC	Not selectable (kPa) p.s.i. bar kPa	0 - 3	PSI					
157	Refrigerant type	0 1 2 3 4 5 6 7 8	nonE 22 502 404A 407A 407b 507A 408A nh3	None R22 R502 R404A R407A R407B R507A R408A Amonia (R717)		Up to v0.00.2					
					0 - 6	22					
					v0.00.3 - v0.00.9						
					1 - 6	22					
					v0.01.0 on						

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
					1 - 8	404A
5.2 Jnet NETWORK AUTOMATIC PRESSURE TRANSDUCER CALIBRATION (v0.01.3 on)						
204	Unadjusted suction pressure					
205	Jnet network zero adjustment status	FroZ LivE	Adjustment frozen Adjustment live			
206	Jnet network zero adjustment					
207	Average suction pressure over last hour at evaporator (defrosts are discounted)					
208	Average suction pressure from plant via network					
209	Suction line pressure drop			xxCx xxOx	0.0 - 10.0	4.0 6.0
154	Force average pressure to current pressure	CLr F.Av.P	Off Force pressure			

JTL COLDSTORE CONTROLLER ITEM NUMBERS						LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE	
				4321			
5.3 ELECTRONIC EXPANSION VALVE CONTROL DATA							
160	Select electronic expansion valve control	OFF E.C.En	OFF Electronic expansion valve control		0 - 1	OFF	
168	Current opening % ((PI x modifier) OR override)						
172	PI output (before modification)						
170	Valve control gain (proportional term)				1 - 100	20	
171	Valve control time constant (integral term)	0 1 - 250	Integral disabled Time constant		0 - 250	20	
162	Minimum Superheat (from v0.01.4 this applies to pressure control strategy only).				0 - 10.0	6.0	
186	Minimum superheat for 2 temperature control (v0.01.4 on)			xxCx xxOx	0 - 5.0 0 - 5.0	4.0 3.0	
163	Maximum Valve opening % (PI)				10 - 100	100	
164	Minimum Valve opening % (PI) (From v0.01.4 this applies to pressure control only).				0 - 50	0	
187	Minimum valve opening % for 2 temperature control (v0.01.4 on)			xxCx xxOx	5 - 50 5 - 50	5 10	
165	Pulsed valve period control	2 3 4 5 6	3.1 4.7 6.25 7.8 9.4	Pulse width period for valve (in seconds) (n/64 x 100 s) where n=setting	2 - 6	6.25	
166	Forced Valve opening %				0 - 100		
167	Force valve shut	OFF F.Sht	Off Forced shut		0 - 1		
169	Current Valve status	OFF PE.on	Off On				
173	Maximum time at minimum output	00:00	Not used		00:00 - 00:10	00:05	
174	High suction pressure shutdown selection	OFF Hp.on	Disabled Enabled		0 - 1	HP.on	

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
5.4 ELECTRONIC EXPANSION VALVE OVERRIDE DATA						
180	Superheat Override status	OFF Or.on	Off Override on			
181	Time since last override (in hr:mn)					
182	Duration of last override (in secs)					
183	Duration of this override (in secs)					
184	Accumulated override time (in secs)					
185	Time since output last modified by override (in hr:mn)					
5.5 ELECTRONIC EXPANSION VALVE MODIFIER DATA						
194	Average temperature error over past 5 mins					
190	Modifier value (%)					
191	Modifier error gain			1 - 100	20	
192	Modifier error adjustment upper limit (%)			1 - 25	10	
193	Time temperature above setpoint before modifier increased			00:01 - 00:20	00:02	
195	Modifier increase time constant			1 - 100	10	
196	Modifier integral term output					

JTL COLDSTORE CONTROLLER ITEM NUMBERS						LCIS				
ITEM	DESCRIPTION	CODE		CODE MEANING	BIT	RANGE	ITEM 9 VALUE			
		4321								
6. INPUTS & OUTPUTS										
70	Operating mode	rEFr dEFr dF.rc dr.dn Li.Ho Pu.dn Sh.dn		Refrigeration Defrost Defrost recovery Drain down Liquid hold off Pump down Shutdown						
71	Inputs	0 IP-1 IP-2 Both	IP- - IP1 - IP- 2 IP12	No inputs Door closed input on Defrost or alarm or shutdown input on Both inputs on						
66	Invert plant input	no YES		Input=alarm No input=alarm		0 - 1	no			
138	Enable shutdown from keyswitch	OFF E.Sd		Disable Enable		0 - 1	OFF			
72	Defrost relay (Function depends on item 75)	0 or OFF dt.on dc.on		Relay deenergised Defrost termination on Defrost control on						
73	Liquid solenoid relay	OFF LS.on		Off Demanding refrig.						
74	Auxiliary heater and fan relays (RL1 & RL2)	0 or OFF Fn.on Hr.on Both		Off Fans on Heater on Both on						
75	Defrost relay mode selection	d.tEr d.Con		Defrost termination Defrost control		up to v0.01.1				
						0 - 1	d.tEr			
						v0.01.2 on				
						0 - 1	d.con			
76	Auxiliary heater OR Suction valve selection (RL1) (Only affect data transmitted to Jnet network)	Off Su.En		Auxiliary heater Suction valve		0 - 1	Off			

JTL COLDSTORE CONTROLLER ITEM NUMBERS						LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE	
				4321			
7. SUCTION PRESSURE OPTIMISATION (v0.01.0 on)							
200	Disable suction pressure optimisation for this unit when both air sensors are faulty	En.SO di.SO	Enable Disable		0 - 1	En.SO	
201	Exclude evaporator from suction pressure optimisation (Data to network)	OFF in.SO	Off Inhibit from suction optimisation				
203	Related suction line from plant controls (Data from network)	0 or nonE Lt Ht SAt	Not selected Low temperature High temperature Satellite				
202	Raw network data for optimiser from plant (Binary data interpreted on item 203)						
211	Evaporator suction group - Required by Mark 2 optimisers (Data to network) (v0.01.5 on)	0 1 2 3	nonE Lt Ht SAt	Not selected Low temperature High temperature Satellite	0 - 3	nonE	
70 (212)	Operating mode	rEFr dEFr dF.rc dr.dn Li.Ho Pu.dn Sh.dn	Refrigeration Defrost Defrost recovery Drain down Liquid hold off Pump down Shutdown				
217	Plant data to network (binary value interpreted on item 211) (v0.01.5 on)						

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		

8. DEFROST CONTROL

8.1 DATA & STRATEGIES

40	Duration of last defrost					
41	Time since end of last defrost					
42	Duration of current defrost					
107 (411)	Defrost strategy	0 1 2 3 4 5 6 7	nonE SL.in n.i.L.b rt.in iP.in nonE nonE n.i.F.b	None Suction initiated Network initiated (learned backup) Internal clock initiated External clock initiated Not used Not used Network initiated (fixed schedule backup)	xxCC xxCO xxOC xxOO	up to v0.01.1
					0 - 4 0 - 4 0 - 4 0 - 4	SL.in SL.in SL.in rt.in
					v0.01.2 to v0.01.3	
					0 - 4	0
					v0.01.4 on	
					0 - 7	0
412	Current defrost initiation strategy in operation (v0.01.7 on)	nonE SL.in JnEt rt.in iP.in	None Suction initiated Jnet network initiated Internal clock initiated External clock initiated		0 - 6	3
69	No of defrosts expected per day	0 1 - 6	Function disabled No of defrosts		00:00 - 00:10	00:00
61	Pump down time					

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS						
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE					
				4321							
8.2 REAL TIME INITIATED DEFROST TIMES											
When a 12 hour schedule is selected (item 60) the defrosts repeat on a 12 hour cycle ie., if 08:00 is selected then a 2nd defrost occurs at 20:00 (and vice versa)											
Daylight saving operation added from v0.01.6. Time and defrost schedule can be automatically displayed as standard time or daylight saving (summer) time if desired. When daylight saving is operational the displayed schedule is automatically adjusted so that defrost still occur at the same "standard time".											
51	Defrost time 1	00:00 00:01 - 23:59	Defrost disabled Defrost enabled	xxCC xxCO xxOC xxOO	00:00 - 23:59 00:00 - 23:59 00:00 - 23:59 00:00 - 23:59	01:00 02:00 03:00 04:00					
52	Defrost time 2	00:00 00:01 - 23:59	Defrost disabled Defrost enabled	xxCC xxCO xxOC xxOO	00:00 - 23:59 00:00 - 23:59 00:00 - 23:59 00:00 - 23:59	07:00 08:00 09:00 10:00					
53	Defrost time 3	00:00 00:01 - 23:59	Defrost disabled Defrost enabled	xxCC xxCO xxOC xxOO	00:00 - 23:59 00:00 - 23:59 00:00 - 23:59 00:00 - 23:59	13:00 14:00 15:00 16:00					
54	Defrost time 4	00:00 00:01 - 23:59	Defrost disabled Defrost enabled	xxCC xxCO xxOC xxOO	00:00 - 23:59 00:00 - 23:59 00:00 - 23:59 00:00 - 23:59	19:00 20:00 21:00 22:00					
55	Defrost time 5	00:00 00:01 - 23:59	Defrost disabled Defrost enabled		00:00 - 23:59	00:00					
56	Defrost time 6	00:00 00:01 - 23:59	Defrost disabled Defrost enabled		00:00 - 23:59	00:00					
60	Defrost schedule selection	24 hr 12 hr	24 hour schedule 12 hour schedule		0 - 1	24 hr					
43	Time next defrost is due										
8.3 SUCTION INITIATED DEFROST											
58	Defrost initiation temperature (suction line sensor)			xxCC xxCO xxOC xxOO	-10 - +20 -10 - +20 +5 - +30 +5 - +30	10 10 15 15					
8.4 CONTACT INITIATED DEFROST											
65	Invert defrost input	no YES	Input=defrost No input=defrost		0 - 1	no					
8.5 Jnet NETWORK INITIATED DEFROST											
46 (215)	Jnet Network initiated defrost command status	P.dEF F.dEF 0 or nonE	Defrost Forced defrost No command								
261 to 272	Defrost schedule (12 times starting at item 261 through to 272) (v0.01.4 on)										

JTL COLDSTORE CONTROLLER ITEM NUMBERS						LCIS						
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE						
				4321								
8.6 DEFROST METHOD DATA (v0.01.5 on)												
This information is for use by defrost schedulers												
211	Evaporator suction group	0 1 2 3	nonE Lt Ht SAT	Not selected Low temperature High temperature Satellite		0 - 3	nonE					
214 (414)	Defrost heater choice	0 1 2 3 4 5 6	rEd YELL bLuE 3 - Ph GAS.2 GAS.3 oFF.C	Electric red phase Electric yellow phase Electric blue phase Electric 3 phase 2 pipe gas 3 pipe gas Off cycle		up to v0.01.6						
						0 - 3	rEd					
						v0.01.7 on						
						0 - 6	rEd					
						up to v0.01.6						
						0 - 7	None					
						v0.01.7 on						
213	Electric circuit choice (depends on item 214)	0 1 2 3 4 5 6 7	nonE cct1 cct2 cct3 cct4 cct5 cct6 cct7	Not electric Circuit 1 Circuit 2 Circuit 3 Circuit 4 Circuit 5 Circuit 6 Circuit 7		1 - 7	cct1					
217	Evaporator data to plant											
219	Jnet network defrost arrangement	nonE cord dEF.S PrEd		None Defrost co-ordinator present on network Timed defrost scheduler present on network Predict co-ordinator present on network								

JTL COLDSTORE CONTROLLER ITEM NUMBERS						LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE	
				4321			
8.7 DEFROST TERMINATION							
144 (413)	Termination method selection (v0.00.8 on)	1 2 3 4	EuAP A.OFF tEr tot	Evaporator sensor Air off sensor Termination sensor Time only	xxCX	1 - 4	
					xxOC	tot	
141	Termination sensor temperature (v0.00.8 on)						
147	Termination sensor selection (v0.00.8 on)	OFF ts.En	Disabled Enabled		0 - 1	OFF	
50	Defrost termination temperature (up to v0.00.7 - evaporator sensor from v0.00.8 - choice on item 144)			xxCC xxCO xxOC xxOO	0 - 30 0 - 30 0 - 30 0 - 30	20 20 15 20	
145	Minimum defrost duration (Defrost heater cycles on termination temperature (item 50) as required during this time) (v0.00.8 on)				00:00 - 00:30	00:10	
57	Maximum defrost duration			xxCx	up to v0.01.0		
					00:05 - 00:45	00:20	
					v0.01.1 on		
				xxOC xxOO	00:05 - 00:59 00:05 - 00:59	00:20 00:40	
				xxCC xxCO xxOC xxOO	00:00 - 00:20 00:00 - 00:20 00:00 - 00:05 00:00 - 00:05	00:10 00:10 00:05 00:02	
59	Drain down duration						
49	Liquid hold off duration (starts when drain down completed)				00:00 - 00:10	00:00	
8.8 DEFROST FORCING FUNCTIONS							
Forced functions remain forced if the Maintenance Unit remains plugged in. They are automatically cancelled 30 minutes after the Maintenance Unit is unplugged.							
77	Forced defrost (Note from v0.00.4 on, when item 107 is indicating Jnet network initiated defrost then forced defrost sends the command to the plant for action. It is NOT actioned locally)	OFF Fd.on	Off Forced defrost on		0 - 1		
78	Inhibit defrost	OFF no.dF	Off No defrosts		0 - 1		
79	Forced refrigeration	OFF Fr.on	Off Forced refrigeration		0 - 1		

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
9. FAN CONTROL						
108	Fan control	F.on F.off	Fan runs always Fan off during defrost		1 - 2	F.off
109	Fan delay after defrost (v0.01.1 on)	00:00	Use evap temp		00:00 - 01:00	00:00
10. DOOR MONITORING						
128	Select door functions	OFF d.iP.E	Disabled Enabled		0 - 1	d.iP.E
34	Time door presently open					
35	Total time door has been open in last 24 hours					
64	Door open refrigeration delay time			xxCC xxCO xxOC xxOO	00:00 - 00:15 00:00 - 00:15 00:00 - 00:30 00:00 - 00:30	00:05 00:05 00:00 00:00
33	Door open alarm delay time				00:00 - 00:30	00:15
126	Coldstore door open critical alarm selection (v0.00.8 on)	non.C Crit	Alarm non critical Alarm critical		0 - 1	non.C
11. Jnet COMMAND FUNCTIONS						
62	Jnet network controlled Shutdown selection	OFF Sh.dn	Disabled Enabled		0 - 1	OFF
63	Jnet network command for shutdown	nonE Sh.dn	No command Shutdown			
133	Enable plant to override temperature control and run refrigeration regardless of the temperature setpoint	Off nrc.E	Disabled Enabled		0 - 1	Off
134	Enable Jnet network command to cut off refrigeration in event of plant fault	Off	Disabled		0 - 1	Off
135	Display Jnet network commands	nonE O.S.df PL.Ft P.C.Ft	No command Other associated systems on defrost Plant fault Plant comms fault			

JTL COLDSTORE CONTROLLER ITEM NUMBERS						LCIS				
ITEM	DESCRIPTION	CODE		CODE MEANING	BIT	RANGE	ITEM 9 VALUE			
		4321								
12. DISPLAY FUNCTIONS										
129	Display type selection (v0.00.1 on)	LED5 LED1				0 - 1	LED5			
122	Temperature display unit choice (v0.01.3 on)	CELS FAhr		Celsius Fahrenheit		0 - 1	CELS			
121	Display pushbutton status	OFF P1.IP	Pb- - Pb1 -	OFF Button 1 pressed						
		v0.01.2 on								
		P2.IP both	Pb- 2 Pb12	Button 2 pressed Both buttons pressed						
122	Display pushbutton 2 status (up to v0.01.1)	OFF P2.IP		Off Button 2 pressed						
13. CLOCK CALENDAR										
Note from version 0.01.3, the time and date can be displayed as standard or daylight saving (summer) time. This choice is made on item 18. When daylight saving is chosen and the controller is connected to a JTL Network Controller supporting daylight saving operation, the change is made automatically to the current EU directive.										
2	Time of day					00:00 - 23:59				
3	Day of week (v0.01.3 on)	Sun - Sat		0 = Sunday 1 = Monday etc						
4	Date (v0.01.3 on)					01:01 - 31:12				
5	Year (v0.01.3 on)					1992 - 2022				
18	Daylight saving enable (v0.01.3 on)	Stnd dAY.S		Standard time Daylight saving time		0 - 1	Stnd			
14. RESTORE FACTORY DEFAULTS										
To set the factory defaults into the memory of the controller, first set the bitswitches as shown, then set item 9 to the set default value of "1234". This should be done on initial commissioning of the unit or when the unit is being installed as a replacement part.										
9	Set default values selected by Bitswitch Note: Setting the bitswitches alone has no effect.	1		Set default value (up to v0.01.2)	xxCC xxCO xxOC xxOO	Frozen food Ice cream Chiller Produce (off cycle) where C = CLOSED or ON O = OPEN or OFF x = Don't care For unmarked switches C = dot visible O = dot not visible				
		1234		Set default values (v0.01.3 on)						
		1066		Write to NVRAM without delay (v0.01.3 on)						

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
15. SYSTEM ALARMS						
80	Group alarm 81 - 88	0 1 - 255	No alarms Check 81 - 88			
81	Air on overtemperature	CLr C.Ht	No fault Fault			
83	Air on sensor fault	CLr AO.Pr	No fault Fault			
84	Air off sensor fault	CLr AF.Pr	No fault Fault			
85	Sensor power supply fault	CLr PS.Ft	No fault Fault			
86	Non critical door open alarm	CLr dO.Ft	No fault Fault			
87	Shutdown alarm	CLr Sh.dn	No fault Fault			
88	All sensors faulty, deselected or disconnected	CLr t.SEn	No fault Fault			
90	Group alarm 91 - 98	0 1 - 255	No alarms Check 91 - 98			
91	Termination sensor fault (v0.00.8 on)	CLr dt.Pr	No fault Fault			
92	Evaporator sensor fault	CLr EP.Pr	No fault Fault			
93	Suction line sensor fault	CLr SL.Pr	No fault Fault			
94	Expected defrosts have not been detected	CLr dEF.F	No fault Fault			
95	Plant alarm	CLr AL.IP	No fault Fault			
96	Critical door open alarm (v0.00.8 on)	CLr dO.Ft	No fault Fault			
97	Excessive Superheat fault (v0.00.8 on)	CLr Hi.Sh	No fault Fault			
98	Pressure Transducer fault (v0.00.3 on)	CLr Pt.FL	No fault Fault			
250	Group alarms 251 - 258 (v0.01.0 on)	0 1 - 255	No alarms Check 251 - 258			
251	Forced defrost activated (v0.01.0 on)	CLr F.dEF	No fault Forced defrost			
252	Network communications failure (v0.01.4 on)	CLr FAIL	No fault Comms failure			
258	Backup defrost strategy in operation (v0.01.5 on)	CLr d.bAc	No fault Backup defrost			

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
16. DIAGNOSTIC & TEST FUNCTIONS						
44	Power off duration					
6	Communications speed (in kilo baud)	4.8 38.4	Baud rate Baud rate			
7	Communications (Half duplex)	HALF	2 wire			
8	Bitswitch setting	0 1 2 3	Frozen food Ice cream Chiller Produce (off cycle)	xxCC xxCO xxOC xxOO		
89	Sensor excitation value (Factory test)		Not used			
99	Test digital display	Clr SET	Not active Test active		0 - 1	
100	Test inputs (v0.01.5 on)	iP - - iP1 - iP - 2 iP12	No inputs Input 1 on Input 2 on Both inputs on			
101	Test output relays (v0.01.2 on)	Clr SET	Not active Test active		0 - 1	
121	Display pushbutton status (v0.01.2 on)	P2.IP both	Pb- 2 Pb12	Button 2 pressed Both buttons pressed		
421	Temperature sensor 1 reading (v0.01.7 on)					
422	Temperature sensor 2 reading (v0.01.7 on)					
423	Temperature sensor 3 reading (v0.01.7 on)					
424	Temperature sensor 4 reading (v0.01.7 on)					
425	Temperature sensor 5 reading (v0.01.7 on)					
10	Processor alarms (11 - 17)	0 1 - 255	No alarms Check 11 - 17			
11	Static RAM fault	Clr RA.Ft	No fault Fault			
12	Program/counter fault	Clr PC.Ft	No fault Fault			
13	Stack pointer fault	Clr SP.Ft	No fault Fault			
14	Background loop fault	Clr bL.Ft	No fault Fault			
15	PROM checksum fault	Clr Pr.Ft	No fault Fault			
16	NVRAM fault	Clr n.Ft	No fault Fault			
17	Instruction TRAP fault	Clr tP.Ft	No fault Fault			
204	Latest polling interval (v0.01.0 - 0.01.2)	min:sec				

JTL COLDSTORE CONTROLLER ITEM NUMBERS					LCIS	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
205	Time since last awake message (v0.01.0 - 0.01.2)	min:sec				
206	Jnet network receive timer (v0.01.0 - 0.01.2)	seconds	(counts down to zero)			
207	Jnet network receive bad character counter (v0.01.0 - 0.01.2)		(counts down to zero)			

DISPLAY DATA		LCIS
NORMAL DISPLAY		
- 99 ^c	Cabinet temperature (item 20 rounded)	
dEF	Defrost	
dEFr	Defrost recovery	
OFF	Shutdown	
FAnS	Fans only	
--	Display data error	
ALARM TEXT (in descending priority order)		
t.SEn	All sensors faulty, deselected or disconnected	
Ht	High cabinet or air off temperature	
AL.IP	External alarm input	
door	Door open alarm	
ISOL	Unit shutdown	
OTHER TEXT		
JTL	Start-up text	
A.on	Air on temperature follows this text	
A.off	Air off temperature follows this text	
EVAP	Evaporator temperature follows this text	
Suct	Suction line temperature follows this text	
T.diF	Superheat temperature follows this text	
L.dEF	Time since last defrost follows this text	
n.dEF	Time of next defrost follows this text	
SEt.P	Coldstore temperature setpoint follows this text	