


TRANSCRITICAL PLANT CONTROL SCHEMATIC



Notes.

1. The high discharge pressure output from the HP350 is linked to the LP462 as a safety interlock.
2. The pressure interlock output from the LP462 is linked to the LP322 as a safety interlock.
3. IF39 Function value set to 3
4. IF31 Function value set to 1



JTL SYSTEMS LTD
41 KINGFISHER COURT, HAMBRIDGE RD,
NEWBURY, BERKSHIRE: RG14 5SJ
TEL: 01635 263646 FAX: 01635 263647

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

04910 ISS 7 March 2020